

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1581

Date: 03-07-2025

This is to certify that the inspection team headed by Prince Kumar, Executive Engineer, P.H. Division, Jamui, inspected the **Tirthankar Mahaveer Vidya Mandir, Veerayatan Lachhuar, Sikandra, Jamui, Bihar** on 27.06.2025 and on the basis of Water Test Report (Attached) by chemist **Mr. Rajesh Kumar dated 27.06.2025 of (PHED Lab)** certified that the Tirthankar Mahaveer Vidya Mandir has safe drinking water facilities for the students and members of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid for six months.

*Prin 1
03.07.25*

Signature with Seal: **Executive Engineer**
Name: Prince Kumar **P.H. Division, Jamui**
Designation: Executive Engineer
Name & Address of the Office / Department
P.H Division, Jamui

To,
The Principal.
Tirthankar Mahaveer Vidya Mandir
Veerayatan Lachhuar, Sikandra

Deepika
Principal
Tirthankar Mahaveer Vidya Mandir
Lachhuar, Sikandra (Jamui)

Anjali Kumar

Anjali Kumar
General Manager
Veerayatan, Bihar

Government of Bihar
Public Health Engineering Department
Division Name :- Public Health Division, Jamui
Water Quality Test Report

District Name :- Jamui

Sample Collected by- School Staff

Date of Sampling:-27.06.2025

Physico-Chemical and Bacteriological Parameters						PH	Turb	EC	TDS	TH	Ca	Mg	Cl	Alkali.	NO3	F	T.Coli	Source of Water	Remarks				
Unit						-	NTU	ymho/cm	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	MPN/100 ml						
Sl. No	Block	Nagar Panchayat	Village	Ward No	Location Details	7	8	9	10	11	12	13	14	15	16	17	18	19	20				
1	2	3	4	5	6	7.43	2.23	476	309	146	32	11	32	161	2.14	0.192	NO	Tubewell					
1	Tirthankar Mahaveer Vidya Mandir, Lachhuar, Sikandara				Boring - 1	6.95	0.79	466	304	142	31	11	31	158	2.08	0.191	NO	Tubewell					
					Boring - 2	6.5-8.5	1.00	-	500	200	75	30	250	200.00	45	1.00	YES / NO						
Desirable Limit*						NR	5.00	-	2000	600	200	100	1000	600.00	NR	1.5							
Permissible Limit* in absence of alternate source																							

Rajesh Kumar
03/07/2025
Chemist

P.H.Division, Jamui

Anjant Kumar
Anjant Kumar
General Manager
Veerayatan, Bihar

Deepika
Principal
Tirthankar Mahaveer Vidya Mandir
Lachhuar, Sikandara (Jamui)