Government of Bihar
Public Health Engineering Department
Division Name :- Public Health Division, Jamui
Water Quality Test Report

t Name :- Jamui

Collected by-SCHOOL STAFF

Date of Sampling:-08.10.2026

hysico-Chemical and Bacteriological Parameters				PH	Turb	EC	TDS	TH	Ca	Mg	Cl	Alkali.	NO3	F	T.Coli	Source of Water	Remarks
Unit				-	NTU	ymho/ cm	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	MPN/100 ml		
Block	Panchayat	Village	Location Details														
2	3	4	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
kandra	Bhullo	Lachhuar	Tirthankar Mahaveer Vidya Mandir, Veerayatan - Lachhuar	7.5	1.8	982	634	302	56	20	45	312	3.48	0.576	NO	Tubewell	
kandra	Bhullo	Lachhuar		7.2	1.0	146	102	48	12	4	10	52	0.32	0.082	NO	RO	
Desirable Limit*				6.5-8.5	1.00	-	500	200	75	30	250	200.00	45	1.00	YES /NO		
Permissible Limit* in absence of alternate source				NR	5.00	-	2000	600	200	100	1000	600.00	NR	1.5			

Rajesh Kumar
Chemist 09/10/2026
P.H.Division, Jamui

Deepak

Principal
Tirthankar Mahaveer Vidya Mandir
Veerayatan Lachhaur, Jamui